

Cuadro No.6
ENERGIA DISPONIBLE EN EL SISTEMA INTERCONECTADO NACIONAL
PERIODO 1995-2004
(GWh)

1 Página de 2

SISTEMA		1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
TOTAL GENERAL											
Total		2,695.8	3,055.7	3,291.0	3,457.8	3,584.0	3,935.8	4,183.5	4,496.6	4,862.9	5,237.1
Hidráulica Estatal		1,672.7	2,039.2	2,085.0	1,923.0	2,136.3	2,260.4	1,903.1	1,609.9	1,737.8	1,371.4
Térmica Estatal		243.9	5.9	45.0	278.3	52.9	6.1	13.7	9.8	32.9	12.6
Energía Comprada		780.0	1,011.1	1,160.2	1,256.3	1,393.1	1,668.5	2,266.6	2,875.3	3,081.3	3,838.5
Energía Inadvertida		-0.7	-0.5	0.8	0.3	1.7	0.8	0.1	1.6	10.9	14.5
SISTEMA INTERCONECTADO NACIONAL											
Total	TECNOLOGIA	2,693.8	3,053.2	3,287.2	3,453.3	3,577.7	3,930.8	4,180.6	4,492.1	4,850.8	5,222.6
Cañaveral	H. REG. ANUAL	149.7	186.0	190.1	170.4	159.3	163.1	164.3	152.4	172.9	149.8
Río Lindo	H. REG. DIARIA	434.1	540.5	559.4	504.6	501.2	508.1	525.9	492.1	540.5	467.4
El Nispero	H. REG. HORARIA	66.3	51.6	54.3	34.2	73.2	36.2	45.6	52.8	36.9	29.6
El Cajón	H. REG. PLURIANUAL	1,019.0	1,257.8	1,278.3	1,212.1	1,396.6	1,552.7	1,165.4	911.3	955.5	702.4
Santa María del Real	H. REG. HORARIA	3.6	3.4	2.9	1.7	6.0	0.0	0.0	0.0	0.5	6.0
El Coyolar	H. REG. HORARIA	0.0	0.0	0.0	0.0	0.0	0.3	2.0	0.4	0.0	0.0
Nacaome	H. REG. ANUAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.9	31.6	16.2
Subtotal		1,672.7	2,039.2	2,085.0	1,923.0	2,136.3	2,260.4	1,903.1	1,609.9	1,737.8	1,371.4
Santa Fe	MDMV	8.7	0.3	3.8	10.9	2.9	0.4	0.1	0.1	4.5	1.5
La Ceiba	MDMV	6.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Danlí	MDMV	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Subtotal	MDMV	15.9	0.3	3.8	10.9	2.9	0.4	0.1	0.1	4.5	1.5
La Puerta	T. Gas	68.9	1.6	12.1	91.5	42.0	0.9	7.8	6.5	16.8	7.7
Miraflores	T. Gas	54.0	0.8	4.5	27.5	0.0	0.0	0.0	0.0	0.0	0.0
Bermejo - MEX	T. Gas	93.9	0.0	20.5	128.2	0.0	0.0	0.0	0.0	0.0	0.0
La Puerta - MEX	T. Gas	8.5	0.2	1.1	15.9	3.4	0.6	3.0	0.3	10.4	3.4
Subtotal		225.2	2.6	38.2	263.1	45.4	1.5	10.8	6.8	27.2	11.1
Energía Comprada		780.0	1,011.1	1,160.2	1,256.3	1,393.1	1,668.5	2,266.6	2,875.3	3,081.3	3,838.5
Energía Inadvertida ¹		-0.7	-0.5	0.8	0.3	1.7	0.8	0.1	1.6	10.9	14.5

¹ Energía Inadvertida: Intercambios de energía no programados, para los años 2002-2004, son desviaciones programadas por el OMCA.

BLOCK1

Cuadro No.6
ENERGIA DISPONIBLE EN EL SISTEMA INTERCONECTADO NACIONAL
PERIODO 1995-2004

Página de 2

SISTEMAS AISLADOS ENEE		1995	1996	1997	1998	1999	2000	2001	2002	2003	2004
(GWH)											
Total	TECNOLOGIA	2.5	3.0	3.0	3.8	4.6	4.2	2.8	2.9	1.2	0.0
Amapala	MDMV	1.7	1.3	1.5	1.6	2.2	1.6	0.0	0.0	0.0	0.0
Utila ²	MDMV	1.1	1.6	1.5	2.2	2.4	2.5	2.8	2.9	1.2	0.0
Subtotal	MDMV	2.8	3.0	3.0	3.8	4.6	4.2	2.8	2.9	1.2	0.0

² El sistema Utila salió del sistema ENEE a partir del mes de junio del año 2003.

BLOCK2