

Cuadro No.13

ENERGIA DISPONIBLE Y PERDIDAS EN EL SISTEMA OPERADO POR ENEE, PERIODO 2004 - 2005

CONCEPTO	2004	2005	Diferencia (MWh)	Variación Porcentual
TOTAL GENERAL				
Consumo Interno Bruto	5,322,332.1	5,540,507.0	218,175.0	4.1
Servicio Propio ENEE	12,682.7	10,555.4	-2,127.3	-16.8
Energía Estatal	1,377,475.9	1,652,964.5	275,488.6	20.0
Energía Comprada en Honduras	3,550,720.9	3,842,628.6	291,907.7	8.2
Intercambio (Importacion-Exportacion)	406,818.0	55,469.4	-351,348.6	-86.4
Energía Neta Aprovechada	4,031,313.1	4,176,357.3	145,044.2	3.6
Energía Vendida	4,010,720.2	4,176,357.3	165,637.1	4.1
Sistema Interconectado Nacional	3,996,212.8	4,172,435.8	176,223.0	4.4
Internacionales	14,507.4	3,921.5	-10,585.9	-73.0
Consumo Edificios ENEE	20,593.0	8,000.3	-12,592.7	-61.2
Análisis de Pérdidas				
Pérdidas Totales (Transm. y Distrib.)	1,291,018.9	1,364,149.7	73,130.8	5.7
Porcentaje de Pérdidas	24.3	24.6	0.4	1.5
SISTEMA INTERCONECTADO NACIONAL				
Consumo Interno Neto	5,237,075.9	5,551,062.5	313,986.6	6.0
Energía Neta Generada por ENEE	1,384,025.9	1,652,964.5	268,938.6	19.4
Energía Comprada	3,838,542.5	3,842,628.6	4,086.1	0.1
Internacionales (Desviaciones enviada - recibida)	14,507.4	55,469.4	40,962.0	282.4
Energía Neta Aprovechada	4,018,630.5	4,184,357.6	165,727.1	4.1
Energía Vendida	3,996,212.8	4,172,435.8	176,223.0	4.4
Ventas Internacionales	14,507.4	3,921.5	-10,585.9	-73.0
Consumo Edificios ENEE	7,910.3	8,000.3	90.0	1.1
Análisis de Pérdidas				
Pérdidas (Transm. y Distrib.)	1,291,018.9	1,364,149.7	73,130.8	5.7
Porcentaje de Pérdidas	24.3	24.6	0.4	1.5